

**S&P Sistemas de Ventilación S.L.U.**

C/ Llevant, 4
08150 Parets del Vallès (Barcelona)
Tel. +34 93 571 93 00
Fax +34 93 571 93 01 +34 93 571 93 11 (Export)
www.solerpalau.com · consultas@solerpalau.com

Declaration of Performance

The manufacturer **SOLER & PALAU Sistemas de Ventilación S.L.U.**

C/Llevant, 4
08150 – Parets del Vallès (Barcelona)

hereby declares that the inlet described below, has the following airflow and sound absorption values:

Product	Airflow (m3/h)	Dn,e,w (C)	Dn,e,w (Ctr)
EC-N 15	15	33	35
EC-N 22	22	33	35
EC-N 30	30	33	34
EC-N 45	45	32	33
ECA 22	22	39	39
ECA 30	30	39	39
ECA 36	36	39	38
ECA 45	45	37	37
ECA-RA 22	22	42	41
ECA-RA 30	30	41	41
ECA-RA 36	36	41	39
ECA-RA 45	45	39	39
EC-HY	6/45	33	34
EC-HY 3F	6/45	33	34
ECA-HY	6/45	37	37
ECA-HY RA	6/45	39	39
SILEM KIT 22	22	50	47
SILEM KIT 30	30	50	47
SILEM KIT HY 125	6/45	50	47
SILEC KIT + EC-N 22	22	49	51
SILEC KIT + EC-N 30	30	49	51
SILEC KIT + EC-N 45	45	50	49
SILEC KIT + ECA-HY 6/45	6/45	52	50

based on the following harmonized standards:

EN 13141-1

EN 51-732

Signed on behalf of the manufacturer by:

Carlos Campderròs,

Parets del Vallès, April 2015